

Product specification Certificate 0766-CPR-488/7

Name of the product: Plywood- Shouguang Luli Wood Inc.		
Class		code
Plywood for internal use in dry conditions (EN 636-1)	1) ✕	2117264-024
Plywood for internal use in humid conditions (EN 636-2)	1) ✕	
Plywood for external use (EN 636-3)	1) ✕	
Application area		
Use as non-structural component	1) ✕	
Use as structural component	1) ✕	
Panel		
Nominal thickness or thickness range [mm]	8~25	
Length [mm]	1820~2440	
Width [mm]	720-1220	
Number of veneers	5~19	
Core veneer		
Kind of wood	Alder, Apitong, Erima, Eucalyptus, Poplar	
Thickness [mm]	1.5-2.0	
Face veneer		
Kind of wood	Apitong, Alder, Almond Birch, Erima, Eucalyptus, Okoume, Poplar, Tropical	
Thickness [mm]	0.3-2.0	
Back veneer		
Kind of wood	Apitong, Alder, Almond Birch, Erima, Eucalyptus, Okoume, Poplar, Tropical	
Thickness [mm]	0.3-2.0	
Adhesive		
Type	PF (Phenol-Formaldehyde Resin)	
Product name	Dynea 14L962	
Further information		
Contains flame retardant	No	
Contains wood preservative	No	

1) Please mark the relevant properties with a cross.

Specification for ITT:

Panel			
Nominal thickness [mm]	12		
Core veneer (wood species, thickness [mm], number)	Poplar, 1.7, 4; 2.0, 3		
Face veneer (wood species, thickness [mm], number)	Indian almond, 0.5, 1		
Back veneer (wood species, thickness [mm], number)	Indian almond, 0.5, 1		
Veneer orientation	- - - -		
Panel properties			
Bending strength [N/mm ²] (L _{5%})	0° / 90°	41.6/33.8	
Bending strength classes	0° / 90°	F25/F20	
Bending modulus [N/mm ²] (L _{5%})	0° / 90°	3321/3143	
Bending modulus classes	0° / 90°	E35/E30	
Mean shear strength [N/mm ²] (and mean apparent cohesive wood failure [%]) ²⁾ (after pre-treatment according to EN 314-1 (depending on bonding class)	5.1.1	[N/mm ²]	[%]
	5.1.2	1.80	68
	5.1.3	1.47	55
	5.1.4	/	/
		1.26	46

2) Value of wood failure is only necessary, if the value of shear strength is smaller than 1.

Comments:

The properties of products which differ in their structure from the ITT structure (thickness, type of wood) are mandatorily to be confirmed by the manufacturer under the FPC, and where necessary, they need to be submitted to the Notified Body.

13 April 2026
date

S. B...
Stamp and signature
B. Eng. Samantha
HOLETECHNOLOGIE
GmbH
SUCCESS BY QUALITY
Zellescher Weg 24 · 01217 Dresden · www.eph-dresden.de